



ADDENDUM NO.1

From: **Tony Chartrand**
Subject: **Project Bid**

Project Name: **Critical & Large Customer #4 Project**
Project No.: **325**
Issue Date: **3/25/2019**
Distribution: **Bidders**

This addendum will answer submitted questions pertaining to the project. This addendum is part of this contract.

1. Contractor to supply the conduit and all required sweeps. This entails approximately 210' of 4", and 270' of 6" conduit to be installed by either trenching or directional bore.
2. Fiberglass or steel sweeps must be used for 6" conduit. PVC is allowed for 4" conduit. PVC sweeps must be a minimum of 48" radius.
3. The outage to complete the work under the railroad will have to be scheduled with the customers. The largest customer only has shutdown availability on Saturdays or Sundays.

Signed: _____