



**Date:** Wednesday, March 24, 2021

**Addendum #:** 2

**Project Name:** Electric Vehicle Charging Stations - Installation

**Bid Due Date:** Friday, March 26, 2021 at 10:00AM EST

This is the final addendum to answer all additional questions received by the deadline, Wednesday, March 24, 2021 at 10:00AM EST.

**1. Is the bond required?**

*Yes, please include bonding in your proposals.*

**2. Can the bids be submitted electronically?**

*Emailed bids will be accepted. Please indicate in the subject line of the e-mail that you are submitting a "Sealed Bid" together with the project description, "EV Charging Stations," and submit your e-mailed bid to [stvardek@tclp.org](mailto:stvardek@tclp.org) by 10:00AM EST on Friday March 26<sup>th</sup>, 2021. Any proposals received after this date and time will not be accepted. Feel free to send a follow-up email to verify we received the proposal.*

**3. Can the wiring be run in a single conduit to the Level II chargers?**

*A single conduit may be used to run wiring from the meter base to the equipment, provided everything meets code. The equipment itself will have individual runs for each port, meaning the wiring will need to split off before it reaches the charging stations.*