



Date: Thursday, December 3, 2020

Addendum #: 3

Project Name: Electric Vehicle Charging Stations

Bid Due Date: Wednesday, December 9, 2020 at 10:00AM EST

CLARIFICATION TO DC FAST CHARGE REQUIREMENT

It was asked in the pre-bid meeting what the kW should be based on for bids, and 62.5 kW output was the standard that was stated at the time. After further review, TCL&P determined it should have been 50 kW. **Please bid the DC Fast chargers for an output to meet or exceed 50 kW.** This will be the baseline, with alternates accepted as an additional item. We apologize for any confusion.

Questions will be accepted on this clarification until Friday December 4, 2020 at 10:00am.