



Date: August 28, 2015

Addendum #: 1

Project Name: Spruce Street Conduit Installation

Bid Due Date: Friday, September 11, 2015, at 10:00 AM

Section 8* (Directional Boring) of the bid specifications states all pipe used for directional boring must be red in color. TCL&P will also accept black pipe with a red stripe.

8. Directional Boring

- A. All pipe for directional boring will be HDPE, SDR 13.5, all red*, and will be supplied by the Contractor. HDPE sweeps shall be either black or all red and shall be supplied by the Contractor. HDPE sweeps shall include a coupling or labor to electrically weld the sweep to the straight pipe.